

# Estimating Risk-aware Flexibility Areas for Electric Vehicle Charging Pools via AC Stochastic Optimal Power Flow

Juan S. Giraldo, *Member, IEEE*, Nataly Bañol Arias, *Member, IEEE*, Pedro P. Vergara, *Member, IEEE*, Maria Vlasίου, Gerwin Hoogsteen, *Member, IEEE*, and Johann L. Hurink, *Member, IEEE*

**Abstract**—This paper introduces an AC stochastic optimal power flow (SOPF) for the flexibility management of electric vehicle (EV) charging pools in distribution networks under uncertainty. The AC SOPF considers discrete utility functions from charging pools as a compensation mechanism for eventual energy not served to their charging tasks. An application of the AC SOPF is described where a distribution system operator (DSO) requires flexibility to each charging pool in a day-ahead time frame, minimizing the cost for flexibility while guaranteeing technical limits. Flexibility areas are defined for each charging pool and calculated as a function of a risk parameter involving the uncertainty of the solution. Results show that all players can benefit from this approach, i.e., the DSO obtains a risk-aware solution, while charging pools/tasks perceive a reduction in the total energy payment due to flexibility services.

**Index Terms**—Electric vehicle, flexibility management, stochastic optimal power flow (SOPF), risk awareness, compensation mechanism.

## NOMENCLATURE

### A. Sets

|                 |                                                          |
|-----------------|----------------------------------------------------------|
| $\Omega_\omega$ | Set of stochastic scenarios                              |
| $\Omega_b$      | Set of nodes                                             |
| $\Omega_K^s$    | Set of breaking points at charging pool $s \in \Omega_s$ |
| $\Omega_N^s$    | Set of charging points at charging pool $s \in \Omega_s$ |
| $\Omega_s$      | Set of nodes with charging pools                         |

$\Omega_T$  Set of time periods

### B. Parameters

|                        |                                                                               |
|------------------------|-------------------------------------------------------------------------------|
| $\alpha_{s,k}$         | Break point value of energy not served at charging pool $s$ and point $k$     |
| $\beta_{s,t}$          | Risk parameter at charging pool $s$ in period $t$                             |
| $\eta_n^a$             | Expected arrival time of charging task $n$                                    |
| $\eta_n^d$             | Expected departure time of charging task $n$                                  |
| $\kappa$               | Number of breaking points                                                     |
| $\Delta t$             | Duration of period $t$                                                        |
| $\pi_\omega$           | Probability of scenario $\omega$                                              |
| $a_{n,\omega}$         | Arrival time of charging task $n$ in scenario $\omega$                        |
| $A_{n,\omega}$         | Characteristics of charging task $n$ in scenario $\omega$                     |
| $c_{s,t}$              | Unitary cost of energy at charging pool $s$ in period $t$                     |
| $d_{n,\omega}$         | Departure time of charging task $n$ in scenario $\omega$                      |
| $E_{n,\omega}$         | Required energy of charging task $n$ in scenario $\omega$                     |
| $h_{s,k}, b_{s,k}$     | Coefficients of the utility function at charging pool $s$ and break point $k$ |
| $\bar{I}_{ij}$         | The maximum allowed current magnitude at branch $i-j$                         |
| $\bar{P}_{s,t}$        | The maximum allowed power of charging pool $s$ in period $t$                  |
| $P_{i,t}^D, Q_{i,t}^D$ | Active and reactive power demands at node $i$ and period $t$                  |
| $R_{ij}, X_{ij}$       | Resistance and reactance of branch $i-j$                                      |
| $\bar{V}$              | The maximum allowed voltage magnitude                                         |
| $\underline{V}$        | The minimum allowed voltage magnitude                                         |
| $V_{ES,t}$             | Voltage at substation node in period $t$                                      |
| $\bar{x}_n$            | The maximum charging power of charging task $n$                               |
| <b>C. Variables</b>    |                                                                               |
| $\rho_{s,t,\omega}$    | Power mismatch for charging pool $s$ in period $t$ and scenario $\omega$      |
| $\phi_{n,\omega}$      | Energy not served to task $n$ in scenario $\omega$                            |
| $\Phi_{s,\omega}$      | Total energy not served at charging pool $s$ in scenario $\omega$             |

Manuscript received: July 26, 2022; revised: October 18, 2022; accepted: November 30, 2022. Date of CrossCheck: November 30, 2022. Date of online publication: December 20, 2022.

This work was financially supported by the Netherlands Enterprise Agency (RVO) – DEI + project 120037 “Het Indië terrein: Een slimme buurtbatterij in de oude weverij”.

This article is distributed under the terms of the Creative Commons Attribution 4.0 International License (<http://creativecommons.org/licenses/by/4.0/>).

J. S. Giraldo (corresponding author) is with the Energy Transition Studies Group, Netherlands Organisation for Applied Scientific Research (TNO), Amsterdam, 1043 NT, The Netherlands (e-mail: [juan.giraldo@tno.nl](mailto:juan.giraldo@tno.nl)).

N. B. Arias, M. Vlasίου, G. Hoogsteen, and J. L. Hurink are with the Department of Electrical Engineering, Mathematics and Computer Science, University of Twente, Enschede, 7522 NB, The Netherlands (e-mail: [m.n.banolarias@utwente.nl](mailto:m.n.banolarias@utwente.nl); [m.vlasίου@utwente.nl](mailto:m.vlasίου@utwente.nl); [g.hoogsteen@utwente.nl](mailto:g.hoogsteen@utwente.nl); [j.l.hurink@utwente.nl](mailto:j.l.hurink@utwente.nl)).

P. P. Vergara is with the Intelligent Electrical Power Grids Group, Electrical Engineering, Mathematics and Computer Science, Delft University of Technology, Delft, 2628 CD, The Netherlands (e-mail: [p.p.vergarabarrios@tudelft.nl](mailto:p.p.vergarabarrios@tudelft.nl)).

DOI: 10.35833/MPCE.2022.000452



|                                    |                                                                                                             |
|------------------------------------|-------------------------------------------------------------------------------------------------------------|
| $\bar{\lambda}_{s,k,\omega}$       | Weights at charging pool $s$ and break point $k$ in scenario $\omega$                                       |
| $\underline{\lambda}_{s,k,\omega}$ |                                                                                                             |
| $\mathcal{Z}_{s,\omega}$           | Auxiliary variable representing the cost of energy not supplied to charging pool $s$ in scenario $\omega$   |
| $\mathcal{R}_{s,t}$                | Flexibility area of charging pool $s$ in period $t$                                                         |
| $I_{ij,t,\omega}^{\text{sqr}}$     | Squared current magnitude flowing through branch $i$ - $j$ in period $t$ and scenario $\omega$              |
| $P_{s,t}$                          | Reserved power for charging pool $s$ in period $t$                                                          |
| $P_{ij,t,\omega}$                  | Active and reactive power flowing through branch $i$ - $j$ in period $t$ and scenario $\omega$              |
| $Q_{ij,t,\omega}$                  |                                                                                                             |
| $V_{i,t,\omega}^{\text{sqr}}$      | Squared voltage magnitude at node $i$ in period $t$ and scenario $\omega$                                   |
| $x_{s,t,\omega}$                   | Allocated power consumption for charging pool $s$ in period $t$ and scenario $\omega$                       |
| $y_{s,k,\omega}$                   | Binary variable representing state of segment at charging pool $s$ and break point $k$ in scenario $\omega$ |

## I. INTRODUCTION

**B**ESIDES being an environmentally-friendly option for transportation, electric vehicles (EVs) can also provide services due to the controllable nature of their load. Examples of these services are, amongst others, congestion management, peak shaving, and frequency regulation [1]. These services may be of increased value as technical problems such as voltage violations and branch overloading are expected to be more likely in distribution systems if no actions are taken [2]. For distribution system operators (DSOs), which are responsible for delivering electricity to end customers and maintaining a reliable network operation, it might be interesting to assess the flexibility needs in their networks. In a later stage, these flexibility needs may also be provided by entities such as aggregators to solve operating issues or offer it as an ancillary service. For this, flexibility areas may be determined corresponding to the range of active power in which flexibility sources can be managed [3].

In [4], it is already stated that network issues can be tackled through flexibility management frameworks to avoid common issues in distribution systems, such as congestion or voltage limit violations. This strategy is known as DSO's flexibility procurement, and it has gained momentum during the last few years due to its economic advantages over other solutions such as grid reinforcement. However, for a flexibility scheme to be successful, it must guarantee that all participants can benefit from participating and are thus willing to engage in the flexibility scheme [5].

Due to driving behaviours, penetration levels, and energy requirements, different EVs add an intrinsic, highly volatile stochasticity layer to the already complex flexibility management problem [6]. Hence, to successfully implement a flexibility scheme, new management mechanisms are needed that incentivise EV users to offer their flexibility and encourage them to participate in such schemes allowing the DSO to guarantee a high-quality delivery service under uncertainty. In this context, a call for flexibility consists of acquiring services from EVs by the DSO to ensure the safe operation of

the grid [3], ensuring that interests of EVs are respected.

Several works have studied flexibility concepts concerning EVs in distribution systems using pricing strategies. For example, [7] proposes a roadmap with key recommendations for the inclusion of EVs, where they define EV flexibility services in terms of power, time, duration, and location. Furthermore, [8] proposes an adaptive pricing strategy that helps to mitigate peak demand and to reduce the need for grid reinforcement. Likewise, in [4], a dynamic pricing strategy for peak load reduction is proposed to optimize the profit of charging pool owners, while the uncertain preferences of customers are accounted for via robust optimization.

Smart charging strategies designed in [9] are able to satisfy multiple flexibility objectives and target specific groups of EV users according to user profile preferences. However, they do not take into account different pricing schemes, aggregator profit, and EV user compensation. Similarly, [10] presents a stochastic optimization model for cooperative control of charging stations using an aggregated energy storage equivalent to describing the charging tasks of EVs. However, although the approaches mentioned above can provide local peak shaving services, they are not designed to consider network constraints. In [11], EV flexibility is provided in the form of peak shaving and valley filling, and pricing and charging scheduling mechanisms are proposed based on a linear demand-price function. The problem is formulated as a bilevel program in which the distribution market clearing is simulated at the lower level and the EV charging scheduling is solved at the upper level. Although aggregated flexibility is calculated for DSO services, the proposed framework is deterministic disregarding the uncertain nature of EV parameters.

The concept of flexibility envelopes is introduced in [12] as an alternative to quantifying flexibility reserves considering the time evolution. This concept has been used, for example, in [13], to show that the flexibility reserves depend highly on the availability of EVs. Furthermore, in [14], flexibility envelopes are calculated for local energy communities highlighting it as an ease-of-use approach for managing and reserving flexibility in real-time. A similar concept known as flexibility areas has been used to estimate the flexibility of the available active and reactive power at the transmission system operator (TSO)-DSO boundary [3]. A bottom-up aggregation is commonly performed to estimate such flexibility areas by determining the potential of different assets at the boundary [15]. In [16], a risk-aware framework is proposed to define the aggregated flexibility from TSO-DSO interconnections and a two-stage linear stochastic optimization model is developed to optimally define the active power flexibility available from DSOs to TSOs via a DC optimal power flow (DC-OPF). Moreover, as concluded in [17], optimal power flow (OPF) based algorithms allow for obtaining more reliable feasible operating regions compared with random sampling methods. However, none of the above approaches does consider uncertainty.

Stochastic programming is a common approach for handling uncertainty in electrical power systems including network constraints [18]. For example, [19] introduces a multi-

period AC stochastic OPF (SOPF) considering different flexibility assets for congestion management and voltage control. A two-stage stochastic programming model for managing the flexibility of EVs is proposed in [20] for distribution systems in which EVs have already been fully recharged. Similarly, [21] uses a linearized power flow model in a stochastic optimization model considering network constraints focusing on the network reliability. Robust optimization is also used as in [22] to provide flexibility of EVs to DSOs through active and reactive power management strategies, which minimizes the amount of non-supplied energy and considers network constraints. A queuing network model for EV charging is presented in [23], where the power allocation is defined in the distribution network while avoiding congestion and voltage issues. However, all these works assume that users agree to participate in the flexibility scheme without taking into account their particular priorities.

The willingness of participants to engage in energy trading is an essential factor to be considered in a flexibility scheme. Different approaches have been identified in the literature, such as solving a global optimization problem that is aware of all participants' subproblems, double auction schemes, and using marginal utility functions [5]. Reference [24] quantifies the EV flexibility for a group of EVs classified by user priorities in terms of amount, time, and duration of availability via a data-driven approach. Even though the EV flexibility is properly quantified, the work focuses on data analysis without explicitly proposing an EV flexibility scheme for practical implementations. Similarly, an online algorithm for charging scheduling of EVs in charging pools is proposed in [25], aiming to optimize the amount of energy, charging time, and prices for EV users, which is able to choose the most preferable option of EV users from a menu-based pricing scheme. Although this work ignores economic profits of each individual charging pool and a detailed operation of the power grid (i.e., power flow equations), its online nature sets it as a promising option for real implementations of EV flexibility schemes. With this, simplified representations for utility functions are common since they allow for using decentralized optimization algorithms. For example, [26] introduces a decentralized flexibility market based on linear utility functions where the prosumers' willingness to participate is explicitly considered. Furthermore, [27] proposes using piecewise-quadratic utility functions. However, as found in [5], utility functions are often nonlinear and nonconvex, and in the case that they are linear, they can be relatively flat with occasionally significant variations, resulting in non-smooth utility functions.

The reviewed studies show that flexibility services via EV charging have been widely studied. However, we have identified three main gaps in the current literature which we attempt to fill with this paper.

1) Most papers dealing with local EV energy management disregard network constraints and do not consider uncertainties. We propose an multi-period AC SOPF considering network constraints and uncertainty related to EV requirements.

2) Most papers consider quadratic utility functions because of their attractive properties. We propose a general

piecewise-linear formulation that is able to deal with convex and nonconvex utility functions allowing us to represent the interests of EV users. The proposed utility functions represent the participants' willingness to offer flexibility services in the form of energy not served in return for compensation.

3) We propose a methodology to estimate risk-aware flexibility areas where the DSO can guarantee operational limits. This is done by introducing a risk parameter representing the willingness of the DSO to withstand operational limit violations. This methodology allows estimating probable costs for flexibility requirements and gives the charging pools more freedom to manage the EV load.

## II. PROBLEM DESCRIPTION

An operator entity, namely the DSO, is responsible for guaranteeing reliable operational conditions in an electrical distribution network. In addition to constraint satisfaction (i.e., voltage and current magnitude limits), the DSO aims to achieve an economically efficient operation on a day-ahead time frame via flexibility procurement. In this context, we consider a distribution network with a set  $\Omega_b$  of nodes, connected by a set of distribution lines. A fixed number of charging pools are connected to the network, identified by the subset  $\Omega_s \subset \Omega_b$ . Hereby, a charging pool  $s \in \Omega_s$  consists of a fixed set  $\Omega_N^s$  of charging points (e.g., the number of EV parking spaces). A charging task  $n$  arriving at the charging pool  $s$  is represented as  $n \in \Omega_N^s$ , and is characterized by its set of requirements  $A_n$ . It is assumed that a truthful local market mechanism [28] is implemented, eliminating any strategic behaviour from the participants, meaning that all charging tasks arriving at a charging pool are willing to provide demand flexibility services in exchange for compensation. This compensation must reflect the charging tasks involved in the process, whether by a tariff reduction, a bonus, or any other kind of settlement [29]. Therefore, the charging pools act as local flexibility aggregators characterized by a utility function  $u_s$  which are able to control the charging profiles of their tasks.

In the implemented market mechanism, the charging pools agree on truthfully communicating the expected requirements of their charging tasks  $A_n$  along with their utility functions  $u_s$  to the DSO. Therefore, the DSO aims to obtain optimal demand profiles for the charging pools, which minimize the cost for flexibility procurement while guaranteeing the safe operation of the network over a planning horizon  $\Omega_T$ . In operation, it would be ideal that the charging pools could provide the required demand profiles, meaning that all operational constraints are satisfied. However, in real operation, the actual delivered power might vary around the planned profiles since the information from the charging pools is intrinsically uncertain, e.g., due to the stochastic behaviour of their charging tasks. Hence, the DSO needs to plan its actions taking into account the operation uncertainties from the charging pools. For this purpose, in this paper, we propose using a multi-period AC SOPF, extending the work in [18].

Let  $\omega \in \Omega_\omega$  be a realization in a set of stochastic scenarios considering possible outcomes due to the uncertainty of the characteristics of the charging tasks. Hence,  $A_{n,\omega}$  represents

the expected requirements of charging task  $n \in \Omega_N^s$  in scenario  $\omega$ . The DSO receives this information from the charging pools and solves the AC SOPF by minimizing the expected costs for flexibility  $\mathcal{Z}_s$  in a day-ahead time frame. The DSO needs to define a risk parameter  $\beta_{s,t}$  based on the risk it is willing to withstand over operational limit violations. Using the optimal solution and the risk parameter, the DSO calculates and communicates a lower and upper power bound to each charging pool valid for each period of the planning horizon. These bounds compose the flexibility area, denoted by  $\mathcal{R}_{s,t}$ . A graphical representation of the day-ahead planning involving the DSO, charging pools, and charging tasks is depicted in Fig. 1 along with its respective section in the paper.




Fig. 1. Interaction between DSO, charging pools, and charging tasks.

In the operation stage, each charging pool  $s$  is responsible for the local flexibility management of its charging tasks considering the flexibility area provided by the DSO. This can be done, for example, using profile steering as in [30]. The actual energy not served to the charging tasks at the end of the day is then aggregated and mapped through the utility function to calculate the actual cost for flexibility.

### III. MATHEMATICAL MODELS

In this section, the different components of the considered setting are presented.

#### A. Charging Tasks

Consider a charging task  $n \in \Omega_N^s$  in charging pool  $s \in \Omega_S$  with a maximum deliverable power  $\bar{x}_n$ . In each scenario  $\omega \in \Omega_\omega$ , a charging task is characterized by the tuple  $A_{n,\omega} = (a_{n,\omega}, d_{n,\omega}, E_{n,\omega})$ . The tuple is composed of the arrival time of the task  $a_{n,\omega} \in \Omega_T$  following a Poisson distribution  $Pois(\cdot)$  characterized by its expected value  $\eta_n^a$  [23], its departure time  $d_{n,\omega} \in \Omega_T$  as a function of the charging duration following an exponential distribution  $Exp(\cdot)$  characterized by the rate  $\eta_n^d$  [31], and the required charging energy  $E_{n,\omega}$  assumed to follow a uniform distribution  $\mathcal{U}(\cdot)$  over the closed interval  $[e_1, e_2]$ :

$$\begin{cases} a_{n,\omega} \sim \text{Pois}(\eta_n^a) \\ d_{n,\omega} \sim \text{Exp}(\eta_n^d) + a_{n,\omega} \\ E_{n,\omega} \sim \mathcal{U}(e_1, e_2) \end{cases} \quad (1)$$

For feasibility, we assume  $a_{n,\omega} < d_{n,\omega} \leq |\Omega_T|$ , and that with-

in the charging period, the required energy can be delivered at full power, i.e.,  $E_{n,\omega} \leq (d_{n,\omega} - a_{n,\omega})\bar{x}_n$ .

It is worth mentioning that the effectiveness of the model is independent of the probability distribution function used to model the exogenous stochastic parameters. In fact, these scenarios can also be mapped from real data [6] or can be synthetically generated [9], [20], [32].

#### B. Charging Pools

A charging pool  $s \in \Omega_S$  gets an energy reserve for its charging operation for a future planning horizon  $\Omega_T$ . The energy reserve is composed of averaged power slots defined before the actual realization  $p_{s,t}$ ,  $\forall t \in \Omega_T$  and eventual power mismatches  $\rho_{s,t,\omega}$  due to the uncertainty of the realizations in each scenario. In other words,  $p_{s,t}$  represents the lower power bound of the charging pool in each period, while  $\rho_{s,t,\omega}$  represents any consumption above that bound. Let  $x_{n,t,\omega}$  be the average power consumption allocated to the charging task  $n \in \Omega_N^s$  during timeslot  $t$  at the realization of scenario  $\omega$ . This is a decision variable determined by the charging pool. Then, the power consumption profile of a charging pool  $s$  in each stochastic scenario is expressed as:

$$p_{s,t} + \rho_{s,t,\omega} = \sum_{n \in \Omega_N^s} x_{n,t,\omega} \quad \forall s \in \Omega_S, t \in \Omega_T, \omega \in \Omega_\omega \quad (2)$$

Equation (2) is limited by an upper bound  $\bar{p}_{s,t}$  representing the power capacity of the connection of the charging pool, e.g., at the transformer, there exists (3) with  $p_{s,t}, \rho_{s,t,\omega} \geq 0$ .

$$0 \leq p_{s,t} + \rho_{s,t,\omega} \leq \bar{p}_{s,t} \quad \forall s \in \Omega_S, t \in \Omega_T, \omega \in \Omega_\omega \quad (3)$$

While the power allocation of each task is bounded by its maximum charging power  $\bar{x}_n$  as shown in (4) and power cannot be allocated to task  $n$  outside the arrival and departure time of the task. Hence,  $x_{n,t,\omega} = 0$  for  $t < a_{n,\omega}$  or  $d_{n,\omega} < t$ .

$$0 \leq x_{n,t,\omega} \leq \bar{x}_n \quad \forall s \in \Omega_S, n \in \Omega_N^s, t \in \Omega_T, \omega \in \Omega_\omega: a_{n,\omega} \leq t \leq d_{n,\omega} \quad (4)$$

Note that vehicle to grid (V2G) can be included by making the left-hand side of (4) smaller than zero, for example, to allow peer-to-peer transactions inside the charging pool [22].

The charging pools also offer flexibility which may imply that some charging tasks end with a lower charged energy than initially requested. This leads to energy not served at task  $n$  in scenario  $\omega$ , defined as  $\phi_{n,\omega}$ :

$$E_{n,\omega} = \sum_{t \in \Omega_T} x_{n,t,\omega} + \phi_{n,\omega} \quad \forall s \in \Omega_S, n \in \Omega_N^s, \omega \in \Omega_\omega \quad (5)$$

For charging pool  $s$ , the total amount of energy not served to its charging tasks is expressed as:

$$\Phi_{s,\omega} = \sum_{n \in \Omega_N^s} \phi_{n,\omega} \quad \forall s \in \Omega_S, \omega \in \Omega_\omega \quad (6)$$

#### C. Discrete Utility Functions

The utility function  $u_s$  of a charging pool  $s \in \Omega_S$  expresses the cost for flexibility as a function of the total energy not served  $\Phi_{s,\omega}$ . It has been recognized that actual utility functions can be highly nonlinear [5] and also not necessarily convex. Therefore, a general formulation is needed to approximate any realistic utility function. To this end, we pro-

pose the use of discretized utility functions using a semicontinuous convex combination formulation [33]. This formulation does not rely on the nature of the utility function (monotonicity or convexity) to approximate it.

An example of a utility function  $u_s$  is shown in Fig. 2, where the dashed line represents a continuous nonlinear function, approximated by a linear piecewise function with three segments.




Fig. 2. Representation of a utility function for a charging pool  $s$  with  $\kappa=3$ .

In this work, we consider a lower-semicontinuous piecewise-linear function representing the utility function of the charging pool  $s$ :

$$u_s = \begin{cases} f_{s,0} = 0 & \Phi_{s,\omega} = 0 \\ f_{s,1} = h_{s,1} \Phi_{s,\omega} + b_{s,1} & 0 < \Phi_{s,\omega} \leq \alpha_{s,1} \\ \vdots & \\ f_{s,\kappa} = h_{s,\kappa} \Phi_{s,\omega} + b_{s,\kappa} & \alpha_{s,\kappa-1} < \Phi_{s,\omega} \leq \alpha_{s,\kappa} \end{cases} \quad (7)$$

where  $k \in \Omega_K^s = \{0, 1, \dots, \kappa\}$ ;  $\{h_{s,k}, b_{s,k}\}$  and  $\{\alpha_{s,k-1}, \alpha_{s,k}\}$  denote the coefficients of the functions and their lower and upper bounds with  $\forall k \geq 1$ , respectively. For the sake of simplicity, we take  $\bar{u}_{s,k-1} := f_{s,k}(\alpha_{s,k-1})$  and  $\underline{u}_{s,k} := f_{s,k}(\alpha_{s,k})$  as the function of segment  $k: k \geq 1$  evaluated on its endpoints. In order to satisfy (7),  $\underline{u}_{s,0} = \bar{u}_{s,0} = \alpha_{s,0} = 0$ .

It must be pointed out that (7) cannot be directly integrated into a mathematical programming model. However, by defining multipliers  $\bar{\lambda}_{s,k,\omega}, \underline{\lambda}_{s,k,\omega} \geq 0, \forall k \in \Omega_K^s$  as the weights at each two endpoints, and binary variables  $y_{s,k,\omega}$ , the utility function can be expressed as a linear combination of the cost of the endpoints:

$$\mathcal{Z}_{s,\omega} = \sum_{k \in \Omega_K^s: k < \kappa} (\underline{\lambda}_{s,k,\omega} \underline{u}_{s,k} + \bar{\lambda}_{s,k,\omega} \bar{u}_{s,k}) + \underline{\lambda}_{s,\kappa,\omega} \underline{u}_{s,\kappa} \quad (8)$$

And the energy not supplied is defined as:

$$\Phi_{s,\omega} = \sum_{k \in \Omega_K^s: k < \kappa} (\underline{\lambda}_{s,k,\omega} + \bar{\lambda}_{s,k,\omega}) \alpha_{s,k} + \underline{\lambda}_{s,\kappa,\omega} \alpha_{s,\kappa} \quad \forall s \in \Omega_S, \omega \in \Omega_\omega \quad (9)$$

To make sure that (8) and (9) lead to a proper representation of the utility function, the following constraints are added:

$$1 = \sum_{k \in \Omega_K^s: k < \kappa} (\underline{\lambda}_{s,k,\omega} + \bar{\lambda}_{s,k,\omega}) + \underline{\lambda}_{s,\kappa,\omega} \quad \forall s \in \Omega_S, \omega \in \Omega_\omega \quad (10)$$

$$\bar{\lambda}_{s,k,\omega} + \underline{\lambda}_{s,k+1,\omega} = y_{s,k+1,\omega} \quad \forall s \in \Omega_S, k \in \Omega_K^s, \omega \in \Omega_\omega: k < \kappa \quad (11)$$

$$\sum_{k \in \Omega_K^s: k \geq 1} y_{s,k,\omega} \leq 1 \quad \forall s \in \Omega_S, \omega \in \Omega_\omega \quad (12)$$

$$y_{s,k,\omega} \in \{0, 1\} \quad \forall s \in \Omega_S, k \in \Omega_K^s, \omega \in \Omega_\omega: k \geq 1 \quad (13)$$

Notice that (10) and (11) ensure that the multipliers are only different from zero in the segment where  $y_{s,k,\omega}$  is activated, while (12) and (13) guarantee that only one segment can be active. Hence, considering the utility functions, the set of variables from the charging pools is defined as  $\mathcal{Y}_{cp} = \{\Phi_{s,\omega}, \mathcal{Z}_{s,\omega}, \bar{\lambda}_{s,k,\omega}, \underline{\lambda}_{s,k,\omega}, y_{s,k,\omega}, x_{n,t,\omega}\}$ .

#### D. Distribution Network Model

We consider a distribution network with radial topology behind an electrical substation denoted by  $ES$  and a set of branches  $\Omega_l \subset \Omega_b \times \Omega_b$ . The operating state of the network for a given scenario  $\omega \in \Omega_\omega$  can be calculated based on the power flow equations as given in constraints (14)-(19), adapted from [34]. Hereby, the active power balance in the network is ensured by (14) and the reactive power balance is given by (15).

$$\sum_{mi \in \Omega_l} P_{mi,t,\omega} - \sum_{ij \in \Omega_l} (P_{ij,t,\omega} + R_{ij} I_{ij,t,\omega}^{sqr}) + P_{i,t,\omega}^G = P_{i,t}^D + \sum_{s \in \Omega_S: s=i} p_{s,t} + \rho_{s,t,\omega} \quad \forall i \in \Omega_b, t \in \Omega_T, \omega \in \Omega_\omega \quad (14)$$

$$\sum_{mi \in \Omega_l} Q_{mi,t,\omega} - \sum_{ij \in \Omega_l} (Q_{ij,t,\omega} + X_{ij} I_{ij,t,\omega}^{sqr}) + Q_{i,t,\omega}^G = Q_{i,t}^D \quad \forall i \in \Omega_b, t \in \Omega_T, \omega \in \Omega_\omega \quad (15)$$

Regular power demands are assumed to be deterministic parameters expressing the base load of all nodes disregarding EVs. Doing this allows us to focus on the impact of EVs. Active and reactive power flows to node  $i$  from its parent node  $m$  are denoted by  $P_{mi,t,\omega}$  and  $Q_{mi,t,\omega}$ , while  $P_{ij,t,\omega}$  and  $Q_{ij,t,\omega}$  are the active and reactive power flows from node  $i$  to its descendant node  $j$ . For the purposes of this work, it is also assumed that the charging stations operate at a unitary power factor and no other controllable power sources such as distributed generators are available in the network, hence  $P_{i,t,\omega}^G = Q_{i,t,\omega}^G = 0, \forall i \in \Omega_b, i \neq ES$ . Also, the voltage magnitude is assumed to be known for the substation ( $V_{ES,t,\omega}^{sqr} = 1.0$  p.u.). The voltage magnitude drop between nodes  $i$  and  $j$  is represented as:

$$V_{j,t,\omega}^{sqr} = V_{i,t,\omega}^{sqr} - 2(R_{ij} P_{ij,t,\omega} + X_{ij} Q_{ij,t,\omega}) - (R_{ij}^2 + X_{ij}^2) I_{ij,t,\omega}^{sqr} \quad \forall ij \in \Omega_l, t \in \Omega_T, \omega \in \Omega_\omega \quad (16)$$

where  $V_{i,t,\omega}^{sqr} := V_{i,t,\omega}^2$  and  $I_{ij,t,\omega}^{sqr} := I_{ij,t,\omega}^2$  are defined to obtain a convex relaxation of the problem [35], while branch power flows are obtained using the rotated second-order cone constraint:

$$V_{j,t,\omega}^{sqr} I_{ij,t,\omega}^{sqr} \geq P_{ij,t,\omega}^2 + Q_{ij,t,\omega}^2 \quad \forall ij \in \Omega_l, t \in \Omega_T, \omega \in \Omega_\omega \quad (17)$$

Furthermore, the upper and lower bounds for nodal voltage and branch current magnitudes are enforced by:

$$\underline{V}^2 \leq V_{i,t,\omega}^{sqr} \leq \bar{V}^2 \quad \forall i \in \Omega_b, t \in \Omega_T, \omega \in \Omega_\omega \quad (18)$$

$$0 \leq I_{ij,t,\omega}^{sqr} \leq \bar{I}_{ij}^2 \quad \forall ij \in \Omega_l, t \in \Omega_T, \omega \in \Omega_\omega \quad (19)$$

Finally, the set of variables from the distribution network is denoted by  $\mathcal{Y}_{dn} = \{V_{i,t,\omega}^{sqr}, I_{ij,t,\omega}^{sqr}, P_{ij,t,\omega}, Q_{ij,t,\omega}, \rho_{s,t,\omega}\}$ .

#### IV. PROPOSED AC SOPF MODEL AND ESTIMATION OF FLEXIBILITY AREAS

##### A. Mathematical Model

Using the mathematical formulations given in the previous section, the proposed AC SOPF is cast as a two-stage stochastic optimization model, formulated as:

$$\begin{cases} \min_{\mathcal{Y}} \left( \sum_{\omega \in \Omega_\omega} \pi_\omega \sum_{s \in \Omega_s} \mathcal{Z}_{s,\omega} - \sum_{t \in \Omega_t} \sum_{s \in \Omega_s} c_{s,t} p_{s,t} \right) \\ \text{s.t. (2)-(6), (8)-(19)} \end{cases} \quad (20)$$

where the set  $\mathcal{Y} = \mathcal{Y}_{cp} \cup \mathcal{Y}_{dn} \cup \mathcal{Y}_{s,t}$  contains the decision variables of the model. The first-stage variables *here-and-now* are  $p_{s,t}$  representing the decisions the DSO takes in advance without knowing the actual realizations, while the second-stage variables *wait-and-see* are  $\mathcal{Y}_{cp}$  and  $\mathcal{Y}_{dn}$ , representing the expected stochastic behavior of the system after fixing the first-stage variables. Note that although DSOs are not allowed to retail electricity, they may procure flexibility from the charging pools, which act as local flexibility aggregators. Hence, the objective function in (20) minimizes the expected value of the cost for flexibility and maximizes the energy reserved for the charging pools.

It must be pointed out that the AC SOPF in (20) is based on a mixed-integer second-order cone programming (MISOCP) problem, which is nonconvex in principle. However, if the two sufficient conditions defined in [35] are satisfied, the relaxed continuous equivalent is convex and exact, and a globally optimal solution is numerically reachable [36]. In the presented model, both conditions are satisfied since the only power source in the system is the substation. Thus, every node only consumes power, and the upper bounds of the voltages are not binding as long as  $V_{ES,t} < \bar{V}$ . Moreover, a numerical solution to (20) can be obtained using the sample average approximation (SAA) technique under different scenario generation methods, e. g., Monte Carlo (MC), moment matching, or point estimate methods [18].

##### B. Estimation of Flexibility Areas

Based on the optimal solution  $\mathcal{Y}^*$  of the AC SOPF in (20), the empirical cumulative density function (eCDF) of  $\rho_{s,t,\omega}^*$  can be calculated, which is denoted as  $F_{\rho_{s,t}^*}$ . Hence, the flexibility area of a charging pool  $s$  in period  $t$  is calculated as:

$$\mathcal{R}_{s,t} = p_{s,t}^* + F_{\rho_{s,t}^*}^{-1}(\beta_{s,t}) \quad (21)$$

where  $\beta_{s,t} \in [0, 1]$ . Notice that the flexibility area  $\mathcal{R}_{s,t}$  is composed of two terms, the power reserve serving as a lower limit  $p_{s,t}^*$  and the upper limit calculated for a specified quantile. It is worth noting that the risk of violating the operational limits and the flexibility area are directly proportional. This means that  $\beta_{s,t} = 0$  represents the most conservative alternative (lowest risk/smallest area), i.e.,  $\mathcal{R}_{s,t} = p_{s,t}^*$  while the most optimistic alternative (highest risk/biggest area) is given for  $\beta_{s,t} = 1$ , leading to  $\mathcal{R}_{s,t} = p_{s,t}^* + \max_{\omega} \{\rho_{s,t,\omega}^*\}$ .

Furthermore, from the perspective of the charging pools, the flexibility area can be interpreted as an accepted operating region to fulfill its charging duties within which the DSO expects to guarantee operational limits. Finally, notice

that  $\mathcal{R}_{s,t}$  can only be obtained after solving (20) since it depends on the optimal solution to uncertain realizations.

#### V. TEST SYSTEM AND SIMULATIONS

In this section, we evaluate the proposed AC SOPF. For the tests, we consider a radial distribution system modified from [34] with 34 nodes, as shown in Fig. 3, which is an 11 kV network with a peak total nominal power of 1.86 MW, 1.23 Mvar,  $\underline{V} = 0.95$  p.u., and  $\bar{V} = 1.05$  p.u.. The maximum phase current at the substation transformer connecting nodes 1-2 is set to be  $\bar{I}_{12} = 88$  A. Four charging pools are placed at nodes 16, 20, 27, and 28, with 30, 59, 36, and 16 charging tasks spread over the planning horizon, respectively. The planning horizon is discretized in 24 one-hour intervals, resembling a day-ahead planning procedure.




Fig. 3. 34-nodes test system including four charging pools.

The shape parameters  $\eta_n^a, \eta_n^d$ , characterizing the arrival and duration time for the EV charging tasks, were obtained considering the data in [9] for weekdays. An MC SAA with  $|\Omega_\omega| = 500$  was used to solve the two-stage AC SOPF (20), considering equiprobable scenarios, i.e.,  $\pi_\omega = 1/|\Omega_\omega|$ . The arrival time and departure time for each scenario were calculated as in (1), while the energy required in each scenario was calculated as  $E_{n,\omega} = \min \{\mathcal{U}(e_1, e_2), \bar{x}_n(d_{n,\omega} - a_{n,\omega})\}$  with  $e_1 = 0$  kWh and  $e_2 = 100$  kWh. Without loss of generality, the maximum power at each charging pool has been set to be  $\bar{p}_{s,t} = 200$  kW, a fixed cost for electricity of  $c_{s,t} = 0.2$  €/kWh was chosen, and the maximum power at each charging task was set to be  $\bar{x}_n = 22$  kW. Finally, the utility functions for the four charging pools have been parameterized as in Fig. 4 with  $\kappa = 3$ .




Fig. 4. Utility functions for four charging pools with  $\kappa = 3$ .

##### A. Obtaining Flexibility Areas – Day-ahead Planning

Two main tests were carried out to determine the flexibility areas. The first one corresponds to the base case, an in-

stance with relaxed voltage and current magnitude constraints and disabled flexibility from charging pools. The base case corresponds to a situation where all required energy from charging tasks is supplied as soon as possible, regardless of the network status. The mean and standard deviation of the minimum voltage magnitude and the maximum branch current in each time period for the base case are shown in Fig. 5. In Fig. 5(a), periods with undervoltage problems can be seen in around the 8<sup>th</sup>-10<sup>th</sup> hour and the 18<sup>th</sup>-20<sup>th</sup> hour. Similarly, periods with overloading problems are evident in Fig. 5(b) around the 18<sup>th</sup>-20<sup>th</sup> hour. These results indicate that the DSO might have a congestion problem during the planning horizon; hence, the flexibility is required.




Fig. 5. Base case results for planning horizon indicating congestion problems. (a) Lowest voltage magnitude. (b) Highest current magnitude.

The second test corresponds to the opposite case, i.e., operational constraints are enforced and flexibility from charging pools is enabled. The resulting value of the objective function found was  $-\text{€}4059.12$  in the base case and  $-\text{€}3908.78$  in the flexibility enabled case. Notice that lower values indicate less energy not served. These results represent a reduction of 3.7% in the total expected payment due to the flexibility cost in the latter case. These results indicate that the charging pools (aggregators) would need to pay for the energy not served to some charging tasks to comply with the DSO's expected flexibility requirements. Consequently, it is expected that the DSO settles this difference with the charging pools as part of a flexibility market [29].

The flexibility areas proposed in Section IV-B allow the DSO to estimate safe operation regions for the charging pools. The first step to obtain the flexibility areas is calculating the empirical eCDF of  $\rho_{s,t,\omega}^*$  based on (21). The eCDF of operating power  $\rho_{s,t,\omega}^*$  of the four charging pools at  $s = \{16, 20, 27, 28\}$  are shown in Fig. 6(a) for the 14<sup>th</sup> hour and in Fig. 6(b) for the 19<sup>th</sup> hour. It can be observed that the expected power areas chosen depend on the period, e.g., for  $\beta_{27}=0.8$ , the operating power needs to be lower than or equal to  $\rho_{27}=49.61$  kW at the 14<sup>th</sup> hour, but lower than or equal to  $\rho_{27}=4.96$  kW at the 19<sup>th</sup> hour. This difference is expected due to the characteristics of the network, i.e., there are some periods when the charging pools can have more room to supply their charging tasks without compromising the operational limits of the network than in other periods. The flexibility area, which finally will be communicated to the charging pools, has been calculated using (21) for both

test cases. In (21), the flexibility area is composed of two terms, the power reserve serving as a lower limit (bold line in Fig. 7) and the upper limit calculated for a specified quantile, as shown in Fig. 7 for  $s=20$  and  $s=27$  using  $\beta_{s,t}=0.9$ . The load shifting is evident when comparing both test cases during the whole time horizon, especially during critical time intervals (the 8<sup>th</sup>-10<sup>th</sup> hour and the 18<sup>th</sup>-20<sup>th</sup> hour).




Fig. 6. eCDFs of operational power  $\rho_{s,t,\omega}^*$  of four charging pools for the 14<sup>th</sup> hour and the 19<sup>th</sup> hour. (a) The 14<sup>th</sup> hour. (b) The 19<sup>th</sup> hour.




Fig. 7. Flexibility area for  $\beta_{s,t}=0.9$  at charging pools  $s=20$  and  $s=27$ . (a) Base case. (b) Flexibility-enabled.

However, load shifting is not always sufficient to solve the congestion problems in this test case. Therefore, the charging pools must also procure flexibility from the charging tasks in the form of energy not served to guarantee the operational limits of the DSO. The probability density function (PDF) of the total energy not served at the four charging pools is presented in Fig. 8(a).




Fig. 8. PDFs of total energy not served and eCDFs of total cost for flexibility at four charging pools. (a) PDFs of total energy not served. (b) eCDFs of total cost for flexibility.

Similarly, Fig. 8(b) presents the eCDF of the total cost for flexibility at each charging pool. It can be observed that the most procured charging pools are  $s=20$  and  $s=27$ , which belong to the same network feeder, as shown in Fig. 3. Interestingly, for this feeder, the most pronounced voltage drops occur; hence, the DSO must procure flexibility in these two

charging pools to solve voltage problems. It is then evident that some charging pools can have an advantageous market position and might behave strategically depending on their location in the network (e.g., due to the radial topology of distribution networks). Therefore, these results reinforce the importance of truthful and fair market mechanisms in future flexibility markets [28], [29].

Moreover, from Fig. 8(b), the DSO can estimate the expected cost for flexibility at each charging pool. For example, using the 90<sup>th</sup> percentile for  $s=27$  means that the total cost for flexibility at that charging pool is expected to be lower than or equal to 48.97 in at least 90% of the expected scenarios.

### B. Validation of Obtained Flexibility Areas with Probabilistic Power Flow – Operation

The next step considers an operation scenario based on the flexibility areas identified for day ahead in Section V-A. Two risk values are tested in this subsection to show the impact of  $\beta_{s,t}$  on the safe operation of the test system. We took arbitrarily risk values  $\beta_{s,t} \in \{0.57, 0.99\}$  for the following analysis. A probabilistic power flow consisting of 5000 MC simulations is executed, considering the uncertainties of the aggregated consumed power at the charging pools. A sequential implementation of the power flow given in [37] has been used due to its convergence and computational characteristics. Uniform distributions are assumed to cope with any scenario combination within the flexibility area defined by the selected risk value of the form  $\sim \mathcal{U}(p_{s,t}, \mathcal{R}_{s,t})$ . It is assumed that the charging pools are able to control their consumption within the required flexibility area. Finally, it must be pointed out that voltage and current magnitude limits are not enforced in the power flow.

At each MC simulation, the lowest voltage and the highest current magnitudes of the test system per time period are stored. In Fig. 9(a), the mean of the lowest voltage magnitude among the buses using both risk values is the continuous line, while the shaded area indicates its maximum/minimum. Similarly, Fig. 9(b) presents the mean of the highest current magnitude and its maximum/minimum. For instance, at the 20<sup>th</sup> hour, the mean of the lowest voltage magnitude for  $\beta_{s,t}=0.57$  is 0.9514 p.u. with a maximum of 0.9522 p.u. and a minimum of 0.9507 p.u.. The maximum current magnitude at the same time has an average of 85.37 A, a maximum of 86.27 A, and a minimum of 84.48 A. On the other hand, for  $\beta_{s,t}=0.99$ , the mean of the lowest voltage magnitude is 0.9499 p.u. with a maximum of 0.9521 p.u. and a minimum of 0.9479 p.u.; while the current magnitude has an mean of 87.43 A, a maximum of 89.95 A, and a minimum of 84.69 A.

The eCDFs of the minimum voltage magnitude considering all time periods are depicted in Fig. 10(a) for both risk values. It can be observed that around 88% of the scenarios violate the voltage limit for  $\beta_{s,t}=0.99$ , whereas for  $\beta_{s,t}=0.57$ , the minimum voltages are always within the limit. The eCDFs of the maximum current magnitude are displayed in Fig. 10(b), where a similar result is obtained with only 10% of the scenarios respecting the maximum current magnitude

limit when  $\beta_{s,t}=0.99$ . These results indicate that the DSO must determine the required flexibility areas based on the risk it is willing to accept since there is a trade-off between the chosen risk value and the probability of violating the operational limits.




Fig. 9. Lowest voltage and highest current magnitudes of test system. (a) Lowest voltage magnitude. (b) Highest current magnitude.




Fig. 10. eCDFs of minimum voltage magnitude and maximum current magnitude. (a) Lowest voltage magnitude. (b) Highest current magnitude.

### C. Impact of Flexibility Areas on Total Payment of Charging Pools

A final test is performed to assess the impact of the flexibility areas on the total payment received by the charging pools. We considered ten risk values used by the DSO, as shown in Fig. 11 for the chosen values. The obtained flexibility areas for different risk values were taken as power limiters for the charging pools, i.e.,  $\bar{p}_{s,t} = \mathcal{R}_{s,t}$ . On the other hand, the total payment, representing the revenue of the charging pools, was calculated as the difference between the cost for the energy delivered to their charging tasks and the cost for energy not served. Thus, positive total payment values are desired to guarantee revenue adequacy [38]. We simulated 1000 random scenarios for each risk value, following the same distributions as described earlier for the random variables. Voltage and current magnitude limits were enforced and the flexibility was enabled.

The obtained results are presented in Fig. 11 using a box plot where the median, the interquartile range, and the 90% confidence intervals are depicted. Results for  $\beta_{s,t}=0.57$  show that the median is  $-\text{€}18.48$ , the interquartile range is limited by  $\text{€}1978.87$  and  $-\text{€}1635.18$ , and the confidence interval is  $\text{€}4021.13$  and  $-\text{€}3826.80$ , respectively; whereas for  $\beta_{s,t}=0.99$  all these values increase considerably. Hence, it can be observed that the total payment for flexibility increases with the risk value, meaning there is a trade-off between the risk the DSO is willing to stand and the revenue of the charging

pools. Interestingly, risk values  $\beta_{s,t} < 0.57$  might produce inadequate revenue situations, which encourages the use of proper compensation mechanisms for energy not served [32]. Consequently, it is expected that the DSO settles this difference with the charging pools as part of a flexibility market [29].




Fig. 11. Total payment from charging pools for different risk values.

## VI. CONCLUSION

In this paper, we propose an AC SOPF for the flexibility management of charging pools in distribution networks introducing the concept of flexibility areas. The AC SOPF considers discrete utility functions for charging pools as a compensation mechanism for eventual energy not served to their charging tasks. The utility functions are presented using a general piecewise-linear formulation to deal with convex and nonconvex prosumer preferences. The aim is to minimize the expected cost for energy not served while satisfying operational constraints. An application of the proposed AC SOPF is described, where a DSO specifies the flexibility area to each charging pool in a day-ahead time frame under uncertainty. This methodology allows estimating probable costs for flexibility requirements and gives the charging pools more freedom to manage the EV load. Results show that a safe flexibility area for charging pools can be used to address DSO's congestion problems, either by load shifting or by managing the energy not served. Moreover, the DSO is able to calculate the flexibility area as a function of a risk parameter  $\beta_s$  and estimate probable costs for flexibility requirements. Results show a trade-off between the risk the DSO is willing to stand and the revenue of the charging pools. At the same time, charging pools and tasks perceive a total energy payment reduction as compensation for the energy not served, which might stimulate charging pool operators and EV users to offer flexibility services (e.g., in a local flexibility market). Future work has to analyze the impact of the proposed flexibility area considering V2G-enabled EVs and reactive power compensation capabilities.

## REFERENCES

- [1] N. B. Arias, S. Hashemi, P. B. Andersen *et al.*, "Distribution system services provided by electric vehicles: recent status, challenges, and future prospects," *IEEE Transactions on Intelligent Transportation Systems*, vol. 20, no. 12, pp. 4277-4296, Jan. 2019.
- [2] G. Hoogsteen, A. Molderink, J. L. Hurink *et al.*, "Charging electric vehicles, baking pizzas, and melting a fuse in Lochem," *CIREN - Open Access Proceedings Journal*, vol. 2017, no. 1, pp. 1629-1633, Jun. 2017.
- [3] J. Silva, J. Sumaili, R. J. Bessa *et al.*, "Estimating the active and reactive power flexibility area at the TSO-DSO interface," *IEEE Transac-*

- tions on Power Systems*, vol. 33, no. 5, pp. 4741-4750, Feb. 2018.
- [4] S. Limmer and T. Rodemann, "Peak load reduction through dynamic pricing for electric vehicle charging," *International Journal of Electrical Power & Energy Systems*, vol. 113, pp. 117-128, Dec. 2019.
- [5] C. Ziras, T. Sousa, and P. Pinson, "What do prosumer marginal utility functions look like? Derivation and analysis," *IEEE Transactions on Power Systems*, vol. 36, no. 5, pp. 4322-4330, Sept. 2021.
- [6] L. Calearo, A. Thingvad, K. Suzuki *et al.*, "Grid loading due to EV charging profiles based on pseudo-real driving pattern and user behavior," *IEEE Transactions on Transportation Electrification*, vol. 5, no. 3, pp. 683-694, Sept. 2019.
- [7] K. Knezović, M. Marinelli, A. Zecchino *et al.*, "Supporting involvement of electric vehicles in distribution grids: lowering the barriers for a proactive integration," *Energy*, vol. 134, pp. 458-468, Sept. 2017.
- [8] K. Valogianni, W. Ketter, J. Collins *et al.*, "Sustainable electric vehicle charging using adaptive pricing," *Production and Operations Management*, vol. 29, no. 6, pp. 1550-1572, Mar. 2020.
- [9] M. Cañigüeral and J. Meléndez, "Flexibility management of electric vehicles based on user profiles: the Arnhem case study," *International Journal of Electrical Power & Energy Systems*, vol. 133, p. 107195, Dec. 2021.
- [10] G. Aragon, E. Gumrukcu, V. Pandian *et al.*, "Cooperative control of charging stations for an EV park with stochastic dynamic programming," in *Proceedings of 45th Annual Conference of the IEEE Industrial Electronics Society*, Lisbon, Portugal, Oct. 2019, pp. 6649-6654.
- [11] R. Xie, W. Wei, Q. Wu *et al.*, "Optimal service pricing and charging scheduling of an electric vehicle sharing system," *IEEE Transactions on Vehicular Technology*, vol. 69, no. 1, pp. 78-89, Jan. 2020.
- [12] H. Nosair and F. Bouffard, "Flexibility envelopes for power system operational planning," *IEEE Transactions on Sustainable Energy*, vol. 6, no. 3, pp. 800-809, Jul. 2015.
- [13] J. Gasser, H. Cai, S. Karagiannopoulos *et al.*, "Predictive energy management of residential buildings while self-reporting flexibility envelope," *Applied Energy*, vol. 288, p. 116653, Apr. 2021.
- [14] H. Nagpal, I.-I. Avramidis, F. Capitanescu *et al.*, "Local energy communities in service of sustainability and grid flexibility provision: hierarchical management of shared energy storage," *IEEE Transactions on Sustainable Energy*, vol. 13, no. 3, pp. 1523-1535, Jul. 2022.
- [15] H. Früh, S. Müller, D. Contreras *et al.*, "Coordinated vertical provision of flexibility from distribution systems," *IEEE Transactions on Power Systems*. doi: 10.1109/TPWRS.2022.3162041
- [16] M. Kalantar-Neyestanaki and R. Cherkaoui, "Risk-aware active power flexibility allocation from TSO-DSO interconnections: the Switzerland's transmission network," *IEEE Systems Journal*. doi: 10.1109/JSYST.2022.3164987
- [17] D. A. Contreras and K. Rudion, "Computing the feasible operating region of active distribution networks: comparison and validation of random sampling and optimal power flow based methods," *IET Generation, Transmission & Distribution*, vol. 15, no. 10, pp. 1600-1612, Jan. 2021.
- [18] J. S. Giraldo, J. C. López, J. A. Castrillon *et al.*, "Probabilistic OPF model for unbalanced three-phase electrical distribution systems considering robust constraints," *IEEE Transactions on Power Systems*, vol. 34, pp. 3443-3454, Sept. 2019.
- [19] M. I. Alizadeh, M. Usman, and F. Capitanescu, "Toward stochastic multi-period AC security constrained optimal power flow to procure flexibility for managing congestion and voltages," in *Proceedings of 2021 International Conference on Smart Energy Systems and Technologies*, Vaasa, Finland, Sept. 2021, pp. 1-7.
- [20] F. Wu and R. Sioshansi, "A two-stage stochastic optimization model for scheduling electric vehicle charging loads to relieve distribution-system constraints," *Transportation Research Part B: Methodological*, vol. 102, pp. 55-82, Aug. 2017.
- [21] W. Sun, F. Neumann, and G. P. Harrison, "Robust scheduling of electric vehicle charging in LV distribution networks under uncertainty," *IEEE Transactions on Industry Applications*, vol. 56, no. 5, pp. 5785-5795, Sept. 2020.
- [22] N. B. Arias, J. C. López, M. J. Rider *et al.*, "Adaptive robust linear programming model for the charging scheduling and reactive power control of EV fleets," in *Proceedings of 2021 IEEE Madrid PowerTech*, Madrid, Spain, Jun. 2021, pp. 1-6.
- [23] A. Aveklouris, M. Vlasios, and B. Zwart, "A stochastic resource-sharing network for electric vehicle charging," *IEEE Transactions on Control of Network Systems*, vol. 6, no. 3, pp. 1050-1061, Sept. 2019.
- [24] N. Sadeghianpourhamami, N. Refa, M. Strobbe *et al.*, "Quantitative analysis of electric vehicle flexibility: a data-driven approach," *International Journal of Electrical Power & Energy Systems*, vol. 95, pp.

- 451-462, Feb. 2018.
- [25] A. Mathioudaki, G. Tsousoglou, E. Varvarigos *et al.*, "Efficient on-line scheduling of electric vehicle charging using a service-price menu," in *Proceedings of 2021 International Conference on Smart Energy Systems and Technologies*, Vaasa, Finland, Sept. 2021, pp. 1-6.
  - [26] T. Morstyn, A. Teytelboym, and M. D. McCulloch, "Designing decentralized markets for distribution system flexibility," *IEEE Transactions on Power Systems*, vol. 34, no. 3, pp. 2128-2139, May 2019.
  - [27] A. Paudel, L. Sampath, J. Yang *et al.*, "Peer-to-peer energy trading in smart grid considering power losses and network fees," *IEEE Transactions on Smart Grid*, vol. 11, no. 6, pp. 4727-4737, Nov. 2020.
  - [28] G. Tsousoglou, J. S. Giraldo, P. Pinson *et al.*, "Mechanism design for fair and efficient DSO flexibility markets," *IEEE Transactions on Smart Grid*, vol. 12, no. 3, pp. 2249-2260, May 2021.
  - [29] G. Tsousoglou, J. S. Giraldo, and N. G. Paterakis, "Market mechanisms for local electricity markets: a review of models, solution concepts and algorithmic techniques," *Renewable and Sustainable Energy Reviews*, vol. 156, p. 111890, Mar. 2022.
  - [30] M. E. T. Gerards, H. A. Toersche, G. Hoogsteen *et al.*, "Demand side management using profile steering," in *Proceedings of 2015 IEEE Eindhoven PowerTech*, Eindhoven, Netherlands, Jun. 2015, pp. 1-6.
  - [31] K. Qian, C. Zhou, M. Allan *et al.*, "Modeling of load demand due to ev battery charging in distribution systems," *IEEE Transactions on Power Systems*, vol. 26, no. 2, pp. 802-810, May 2011.
  - [32] J. S. Giraldo, N. B. Arias, E. M. S. Duque *et al.*, "A compensation mechanism for EV flexibility services using discrete utility functions," in *Proceedings of 2022 IEEE PES Innovative Smart Grid Technologies Conference Europe (ISGT-Europe)*, Novi Sad, Serbia, Oct. 2022, pp. 1-6.
  - [33] J. P. Vielma, A. B. Keha, and G. L. Nemhauser, "Nonconvex, lower semicontinuous piecewise linear optimization," *Discrete Optimization*, vol. 5, no. 2, pp. 467-488, May 2008.
  - [34] J. S. Giraldo, J. A. Castrillon, and C. A. Castro, "Energy management of isolated microgrids using mixed-integer second-order cone programming," in *Proceedings of 2017 IEEE PES General Meeting*, Chicago, USA, Jul. 2017, pp. 1-5.
  - [35] L. Gan, N. Li, U. Topcu *et al.*, "Exact convex relaxation of optimal power flow in radial networks," *IEEE Transactions on Automatic Control*, vol. 60, no. 1, pp. 72-87, Jan. 2015.
  - [36] P. Bonami, L. T. Biegler, A. R. Conn *et al.*, "An algorithmic framework for convex mixed integer nonlinear programs," *Discrete Optimization*, vol. 5, no. 2, pp. 186-204, May 2008.
  - [37] J. S. Giraldo, O. D. Montoya, P. P. Vergara *et al.*, "A fixed-point current injection power flow for electric distribution systems using Laurent series," *Electric Power Systems Research*, vol. 211, p. 108326, Oct. 2022.
  - [38] H. Ming, A. A. Thatte, and L. Xie, "Revenue inadequacy with demand response providers: a critical appraisal," *IEEE Transactions on Smart Grid*, vol. 10, no. 3, pp. 3282-3291, May 2019.

**Juan S. Giraldo** received the B.Sc. degree in electrical engineering from the Universidad Tecnológica de Pereira, Pereira, Colombia, in 2012, and the M.Sc. and Ph.D. degrees in electrical engineering from the University of Campinas (UNICAMP), Campinas, Brazil, in 2015 and 2019, respectively. From October 2019 to May 2021 he was a Postdoctoral Fellow at the Department of Electrical Engineering, Eindhoven University of Technology, Eindhoven, The Netherlands (NL). Later, from June 2021 to August 2022 he was a Postdoc with the Mathematics of Operations Research Group at the University of Twente, Enschede, NL. He is currently a Researcher with the Energy Transition Studies Group with the Netherlands Organisation for Applied Scientific Research (TNO), Amsterdam, NL. His current research interests include optimization, planning, and control of energy systems, energy markets, and machine learning applied to energy systems.

**Nataly Bañol Arias** received the B.Sc. degree in production engineering from the Universidad Tecnológica de Pereira, Pereira, Colombia, in 2012, and the M.Sc. and Ph.D. degrees in electrical engineering from the São Paulo State University (UNESP), Ilha Solteira, Brazil, in 2015 and 2019, respectively. Currently, she is a Researcher at the University of Twente, Enschede,

The Netherlands. Her current research interests include development of methodologies for optimization, planning, and control of modern distribution systems including electric vehicles and renewable energy sources, energy management systems, and flexibility markets.

**Pedro P. Vergara** received the B.Sc. degree (with honors) in electronic engineering from the Universidad Industrial de Santander, Bucaramanga, Colombia, in 2012, and the M.Sc. degree in electrical engineering from the University of Campinas, Campinas, Brazil, in 2015. In 2019, he received his Ph.D. degree from the University of Campinas and the University of Southern Denmark, Odense, Denmark, funded by the Sao Paulo Research Foundation (FAPESP). In 2019, he joined the Eindhoven University of Technology (TU/e), Eindhoven, The Netherlands, as a Postdoctoral Researcher. In 2020, he was appointed as Assistant Professor at the Intelligent Electrical Power Grids (IEPG) Group at Delft University of Technology, Delft, The Netherlands. He has received the Best Presentation Award at the Summer Optimization School in 2018 organized by the Technical University of Denmark (DTU), Copenhagen, Denmark and the Best Paper Award at the 3rd IEEE International Conference on Smart Energy Systems and Technologies (SEST), in Turkey, in 2020. His main research interests include development of methodologies for control, planning, and operation of electrical distribution systems with high penetration of low-carbon energy resources (e.g. electric vehicles, PV systems, electric heat pumps) using optimization and machine learning approaches.

**Maria Vlasiou** received the B.Sc. (Hons.) degree from the Aristotle University of Thessaloniki, Thessaloniki, Greece, in 2002, and the Ph.D. degree from the Eindhoven University of Technology (TU/e), Eindhoven, The Netherlands, in 2006. She is currently a Professor at the University of Twente, Twente, The Netherlands, an Associate Professor at the TU/e, and Research Fellow of the European Research Institute EURANDOM. In 2006, she moved to the H. Milton Stewart School of Industrial and Systems Engineering, at the Georgia Institute of Technology, Atlanta, USA, where she first worked as a Research Engineer and later as a Postdoctoral Fellow. She has been invited to more than 20 foreign universities for collaboration and seminars. She has been Associate Editor in four journals and has refereed for about 45 international journals, conferences, and national science foundations. Her research so far has been funded by grants from more than 10 science foundations, universities, societies, and organisations. She is the co-author of more than 50 refereed papers, the co-recipient of the best paper award in ICORES 2013, the Marcel Neuts student paper award in MAM8, a prize at the 8th Conference in Actuarial Science, and the recent winner of the INFORMS UPS G. Smith award. Her research interests centre on stochastic processes and stochastic operations research. Her research focuses on the performance of stochastic processing networks with layered architectures and on perturbation analysis for heavy-tailed risk models. Other interests include Lévy processes, large deviations for non-monotone stochastic recursions, and proportional fairness in heavy traffic for bandwidth-sharing networks.

**Gerwin Hoogsteen** received the Ph.D. degree from the University of Twente, Enschede, The Netherlands, in 2017 with his thesis "A Cyber-physical Systems Perspective on Decentralized Energy Management". He is currently employed as permanent Researcher in the field of smart grids within the Computer Architecture for Embedded Systems chair, with a focus on applying theoretical research in field-tests. He is the founder and maintainer of the DEMKit and ALPG software. His research interest is in energy management for smart grids, and in particular where it concerns multi-disciplinary research and cyber-physical systems. His current research interests include use of machine learning and artificial intelligence in smart grids, distributed coordination, and cyber-security of smart grids.

**Johann L. Hurink** received the Ph.D. degree from University of Osnabrück, Osnabrück, Germany, in 1992, for a thesis on a scheduling problem occurring in the area of public transport. Since 2009 he is a Full Professor at the University of Twente, Enschede, The Netherlands, and since 2020 also the Director of the 4TU Applied Mathematics Institute (AMI), The Netherlands. His current research mainly focuses on optimization and control problems for energy management and smart grids.